

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. 32/1/196

Water Right Permit No. _____

(1) OWNER: Name John Resich Address 840W 9TH S SAN PEDRO CALIF 90131

(2) LOCATION OF WELL: County ISLAND SW NE Sec. 19 T. 32 N. R. 1E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) W. Zylstra RD, Coupeville WA 98277

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐
☐ Irrigation ☐ Test Well ☐ Other ☐
☐ DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one) 1
Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 230 feet. Depth of completed well 230 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 220 ft.
Welded ☐ " Diam. from _____ ft. to _____ ft.
Liner installed ☐ " Diam. from _____ ft. to _____ ft.
Threaded ☐ " Diam. from _____ ft. to _____ ft.

Perforations: Yes ☐ No ☒

Type of perforator used _____

SIZE of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

Screens: Yes ☒ No ☐

Manufacturer's Name COOK
Type STAINLESS STEEL Model No. 304
Diam. 6 Slot size 10 from 220 ft. to 225 ft.
Diam. 6 Slot size 12 from 225 ft. to 230 ft.

Gravel packed: Yes ☐ No ☒ Size of gravel _____
Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes ☒ No ☐ To what depth? 18+ ft.
Material used in seal BENTONITE

Did any strata contain unusable water? Yes ☐ No ☒
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(7) PUMP: Manufacturer's Name _____
Type: _____ H.P.

(8) WATER LEVELS: Land-surface elevation 210- ft.
Static level 179 ft. below top of well Date 10-92
Artesian pressure _____ lbs. per square inch Date _____
Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☒ If yes, by whom? _____
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)
Time Water Level Time Water Level Time Water Level

Date of test _____

Boiler test 15 gal./min. with 15 ft. drawdown after 2 hrs.

Airtest _____ gal./min. with stem set at _____ ft. for _____ hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water _____ Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
HARD PAN	0	57
DRY SAND	57	107
SANDY CLAY	107	144
WATER SAND - FINE	144	150
CLAY	150	210
WATER SAND - GOOD	210	230

RECEIVED

OCT 14 1992

DEPT. OF ECOLOGY

Work started oct 1992 completed oct 6 1992

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME WHIDBEY DRILLERS
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address OAK HARBOR WA.

(Signed) Perrin Fote License No. 129
(WELL DRILLER)

Contractor's
Registration
No. WHIDBWD289MM Date oct 6 1992

(USE ADDITIONAL SHEETS IF NECESSARY)

